

System	Water outlet temp (°C)	Ambient temperature (°C WB)																																
		-20			-15			-10			-7			-2			2			7			12			15			20			25		
		CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP			
RASM-5(V)TW2E	75	-	-	-	-	-	-	-	-	-	8.59	5.62	1.53	8.22	5.25	1.57	7.93	4.95	1.60	8.80	5.18	1.70	7.72	3.17	2.44	7.72	3.17	2.44	7.72	3.17	2.44			
	70	-	-	-	-	-	-	-	-	-	8.28	5.47	1.51	8.30	5.05	1.64	8.32	4.72	1.76	8.93	3.95	2.26	8.26	2.98	2.77	8.26	2.98	2.77	8.26	2.98	2.77			
	65	-	-	-	9.36	5.81	1.61	9.66	5.69	1.70	9.84	5.61	1.75	10.72	6.02	1.78	10.44	5.78	1.81	12.11	5.12	2.37	11.33	4.13	2.74	11.33	4.13	2.74	11.33	4.13	2.74			
	60	8.56	5.13	1.67	9.74	6.02	1.62	10.13	5.83	1.74	10.37	5.72	1.81	11.29	5.72	1.98	11.39	5.10	2.23	12.82	3.75	3.42	12.46	3.48	3.58	12.46	3.48	3.58	12.46	3.48	3.58			
	55	8.57	5.87	1.46	9.89	5.87	1.69	11.16	5.87	1.90	11.93	5.87	2.03	11.41	5.27	2.17	12.00	5.33	2.25	14.00	4.50	3.11	14.36	3.71	3.87	14.36	3.71	3.87	14.36	3.71	3.87			
	50	8.40	5.24	1.60	9.47	4.92	1.92	10.87	5.07	2.15	11.72	5.15	2.27	12.02	5.19	2.32	12.26	5.21	2.35	14.13	3.87	3.65	13.91	3.24	4.30	13.91	3.24	4.30	13.91	3.24	4.30			
	45	8.75	5.15	1.70	9.68	4.53	2.14	11.40	4.81	2.37	12.43	4.98	2.49	12.63	5.11	2.47	12.78	5.20	2.46	13.75	3.15	4.37	13.46	2.77	4.86	13.46	2.77	4.86	13.46	2.77	4.86			
	40	8.87	4.34	2.04	9.96	4.19	2.38	11.46	4.64	2.47	12.36	4.91	2.52	12.62	4.81	2.63	12.83	4.72	2.72	14.15	3.52	4.02	13.78	2.54	5.42	13.78	2.54	5.42	13.78	2.54	5.42			
	35	8.99	3.53	2.55	10.25	3.85	2.66	11.53	4.47	2.58	12.30	4.84	2.54	12.62	4.51	2.80	13.00	4.30	3.02	14.00	3.55	3.94	14.10	2.31	6.09	14.10	2.31	6.09	14.10	2.31	6.09			
	30	9.45	3.65	2.59	10.02	4.02	2.49	11.49	4.15	2.77	12.37	4.23	2.93	12.02	3.57	3.36	12.22	3.24	3.77	14.67	2.52	5.83	14.50	2.12	6.83	14.50	2.12	6.83	14.50	2.12	6.83			
	25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	11.96	2.84	4.22	14.34	2.56	5.59	15.39	2.47	6.23	15.39	2.47	6.23	15.39	2.47	6.23			
	20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	11.96	2.84	4.22	14.34	2.56	5.59	15.39	2.47	6.23	15.39	2.47	6.23	15.39	2.47	6.23			