

System	Water outlet temp (°C)	Ambient temperature (°C WB)																																
		-20			-15			-10			-7			-2			2			7			12			15			20			25		
		CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP	CAP (kW)	IPT (kW)	COP			
RASM-6(V)TW2E	75	-	-	-	-	-	-	-	-	-	8.59	5.62	1.53	8.22	5.25	1.57	7.93	4.95	1.60	9.91	6.29	1.58	10.56	4.43	2.38	10.56	4.43	2.38	10.56	4.43	2.38	10.56	4.43	2.38
	70	-	-	-	-	-	-	-	-	-	8.28	5.47	1.51	8.30	5.05	1.64	8.32	4.72	1.76	9.79	4.40	2.22	10.35	3.81	2.71	10.35	3.81	2.71	10.35	3.81	2.71	10.35	3.81	2.71
	65	-	-	-	9.36	5.81	1.61	9.66	5.69	1.70	9.84	5.61	1.75	10.72	6.02	1.78	11.42	6.36	1.80	12.11	5.12	2.37	12.05	4.71	2.56	12.05	4.71	2.56	12.05	4.71	2.56	12.05	4.71	2.56
	60	8.56	5.13	1.67	9.74	6.02	1.62	10.13	5.83	1.74	10.37	5.72	1.81	11.29	5.72	1.98	12.04	5.72	2.11	14.06	4.34	3.24	15.38	4.32	3.56	15.38	4.32	3.56	15.38	4.32	3.56	15.38	4.32	3.56
	55	9.10	6.48	1.40	10.54	6.48	1.63	12.05	6.48	1.86	12.96	6.48	2.00	12.86	6.26	2.05	13.00	6.18	2.10	16.00	5.45	2.94	15.67	4.14	3.79	15.67	4.14	3.79	15.67	4.14	3.79	15.67	4.14	3.79
	50	9.48	6.83	1.39	10.53	5.94	1.77	12.05	6.04	2.00	12.97	6.10	2.13	13.40	6.11	2.19	13.75	6.12	2.25	15.92	5.03	3.16	15.49	3.67	4.22	15.49	3.67	4.22	15.49	3.67	4.22	15.49	3.67	4.22
	45	9.87	7.18	1.37	10.52	5.40	1.95	12.05	5.60	2.15	12.97	5.72	2.27	13.94	5.95	2.34	14.72	6.14	2.40	16.05	4.69	3.42	15.30	3.20	4.79	15.30	3.20	4.79	15.30	3.20	4.79	15.30	3.20	4.79
	40	9.73	5.53	1.76	10.75	4.80	2.24	12.13	5.26	2.31	13.20	5.65	2.34	13.85	5.58	2.48	14.57	5.63	2.59	15.89	4.80	3.31	16.37	3.16	5.19	16.37	3.16	5.19	16.37	3.16	5.19	16.37	3.16	5.19
	35	9.59	3.87	2.48	10.98	4.21	2.61	12.21	4.91	2.48	13.50	5.55	2.43	13.76	5.21	2.64	14.50	5.15	2.82	16.00	4.74	3.38	15.72	2.76	5.70	15.72	2.76	5.70	15.72	2.76	5.70	15.72	2.76	5.70
	30	10.64	3.92	2.71	10.83	4.69	2.31	12.28	4.64	2.65	13.50	4.73	2.85	13.76	4.18	3.29	14.26	3.84	3.72	17.29	3.61	4.79	17.45	2.63	6.63	17.45	2.63	6.63	17.45	2.63	6.63	17.45	2.63	6.63
	25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	14.18	2.84	5.00	16.31	2.56	6.36	19.02	3.85	4.94	19.02	3.85	4.94	19.02	3.85	4.94	19.02	3.85	4.94
	20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	14.18	2.84	5.00	16.31	2.56	6.36	19.02	3.85	4.94	19.02	3.85	4.94	19.02	3.85	4.94	19.02	3.85	4.94